



Fire Systems Fire Sprinkler System Dry Pipe Valves (21 05 00)

For questions regarding this section contact: Physical Plant
KKilts@albany.edu

Part 1 – General

- When dry pipe sprinkler systems are specified, the new or replacement dry pipe fire sprinkler valves shall be of the external resting type only.

Part 2 – Product

- Basis of design Tyco DPV-1 or equivalent